



CITY of NOVI CITY COUNCIL

Agenda Item K
July 10, 2017

SUBJECT: Approval of Zoning Ordinance Text Amendment 18.281 to amend the City of Novi Zoning Ordinance at Article 5.15, Exterior Building Wall Façade Materials within Article 5.0, Site Standards, to update the façade ordinance standards, in order to clarify and update the façade materials standards in the zoning ordinance. **SECOND READING**

SUBMITTING DEPARTMENT: Community Development Department – Planning *Baub*

CITY MANAGER APPROVAL: 

BACKGROUND INFORMATION:

The City of Novi Zoning Ordinance contains a section commonly referred to as the "Façade Ordinance" under Article 5: Site Standards, Section 5.15: Exterior Building Wall Façade Materials. Over the years it has come to the attention of staff and the City's Architectural Façade consultant that there are several areas where further ordinance clarifications are needed, as well as updates to include new materials available to applicants in the construction of exterior building wall materials. The significant changes to Section 5.15 listed below are proposed at this time:

- **Use of light and illumination** (Sec. 5.15.2)
Clarification that the use of interior or exterior light or color-changing illumination is not allowed. This is also noted in the notes section of the table.
- **Slope of Roof** (Sec. 5.15.5)
The façade materials calculation incorrectly states the ratio of roof slope that is considered façade. A change to three on twelve (3:12) slope from six on twelve (6:12) slope is proposed since even at a 3:12 slope a building's roof is very visible and visually impactful.
- **Painting of Brick** (Sec. 5.15.6)
It has been the City's interpretation of the ordinance that painted brick is not allowed because natural clay brick is a listed material and painted brick is not listed. The proposed changes plainly state that brick is not to be painted, and only if there is a pre-existing condition may the painting of brick be considered. Painted brick is very hard to maintain and is often left flaking and peeling by property owners. Therefore, in order to maintain a vibrant, attractive community, the ordinance will now clearly stated that painted brick is not allowed.
- **Schedule of Regulating Façade Materials** (Sec. 5.15)
The notes in the chart are further refined to reflect in the field standards, correct errors, and which Regions certain percentages and notes apply. In addition, the chart is updated to include new and to clarify existing material types. The referenced notes to table include changes that correct many Section 9 Façade Waiver requests (see attached review of Section 9 Façade Waiver Review 2015-2016).

Staff reached out to fifteen architects who recently provided façade drawings to the Planning Department to determine if there were any comments or concerns with the changes being

proposed. One response was received supporting the changes with an additional comment that additional area should be allowed for flat metal panels in the TC and TC-1 Districts (greater than the 15% currently allowed). Those comments are attached to this packet. Based on this comment and review by staff and the façade consultant, note number nine has been adjusted to allow 25% flat metal panels in the TC and TC-1 districts.

The Planning Commission held a Public Hearing on April 19, 2017 and provided a favorable recommendation to the City Council. On June 19, 2017, the City Council considered and approved the First Reading with no changes suggested. The Ordinance is now ready for consideration and adoption for its Second Reading.

RECOMMENDED ACTION: Approval of Zoning Ordinance Text Amendment 18.281 to amend the City of Novi Zoning Ordinance at Article 5.15, Exterior Building Wall Façade Materials within Article 5.0, Site Standards, to update the façade ordinance standards, in order to clarify and update the façade materials standards in the zoning ordinance. **SECOND READING**

TEXT AMENDMENT 18.281
FAÇADE ORDINANCE UPDATE
CLEAN VERSION

STATE OF MICHIGAN
COUNTY OF OAKLAND
CITY OF NOVI
ORDINANCE NO. 17-18.281

AN ORDINANCE TO AMEND THE CITY OF NOVI CODE OF ORDINANCES, ORDINANCE 14-271, THE CITY OF NOVI ZONING ORDINANCE, ARTICLE 5.0 "SITE STANDARDS," SECTION 5.15, "EXTERIOR BUILDING WALL FAÇADE MATERIALS," TO CLARIFY AND UPDATE THE FAÇADE MATERIALS STANDARDS IN THE ZONING ORDINANCE.

THE CITY OF NOVI ORDAINS:

Part I. That the City of Novi Code of Ordinances, Ordinance 14-271, the Zoning Ordinance, is hereby amended, by amending Article 5.0, "Site Standards," Section 5.15, "Exterior Building Wall Façade Materials," to read as follows in its entirety:

Section 5.15 - EXTERIOR BUILDING WALL FAÇADE MATERIALS

Introductory paragraphs to section [Unchanged]

1. [Unchanged].
2. Color. Colors of all facade and roof materials proposed for a building reviewed under this Ordinance shall be established by the applicant as an integral part of the building design, and shall exhibit evidence of coordination and selection with respect to the overall visual effect of the building. The color of each facade material shall be harmonious with the color of all other facade materials used on the same building, as well as the color of facade materials used on adjacent buildings. For the purpose of this Ordinance, harmonious shall be defined as colors which are complementary in hue, tone, and intensity. The use of dissonant and/or intense colored facade materials shall be deemed inconsistent with this Section. The use of facade materials to form a background or component in a sign or to increase the visual presence of the building for the purpose of advertising and the use of interior or exterior neon, LED, or flashing or changing-color illuminated features shall be deemed inconsistent with this Section.
3. [Unchanged].
4. Submittals. The following shall be submitted to the Community Development Department. There shall be minimum requirements and the applicant may present other items, as may be deemed necessary by the applicant. All materials submitted shall be retained by the Community Development Department until the final façade inspection is completed, shall become part of the approval documents for the project and may be used by the Community Development Department at a later date to determine compliance of the completed building.

A.- E. [Unchanged].

5. Facade Material Calculations. The facade (north, south, east, and west) of each regulated structure shall be considered separately for the purpose of calculating the percentages of materials for compliance with the Schedule Regulating Facade Materials. The materials on each facade shall be consistent with the materials on other facades of the same building with respect to type and color. Areas of sloped roofs with a slope of three to twelve (3:12) or greater shall be considered facades. Areas of sloped roofs shall be taken as the horizontal projection of the roof area (as seen in elevation view). Areas of vision glass and operable doors shall be excluded from all area calculations.

6. Alterations. Where new materials are proposed for an existing building facade, the entire building facade shall be subject to this Section. Exception where horizontal offsets greater than two (2) feet occur in an existing facade which serve to visually separate the area within which the new materials are proposed, only the area between such offsets shall be subject to this Section, provided that the new materials and colors are harmonious with adjacent unaltered portions of the building, and provided that the building is not located in the TC or TC-1 district. A continuation of existing materials may be used on an alteration. Painting for maintenance that matches the exact color, does not require a permit. Painting for a color change requires review by the Community Development Department prior to work. Painting using colors that are inconsistent with Section 5.15.2 and painting of previously unpainted brick is not allowed.

7.-14. [Unchanged].

5.15 Schedule Regulating Façade Materials			
Façade Regions ⁽⁶⁾			
Region 1	Buildings located in the TC, TC-1, RC, RA, R, RM-1, RM-2, PSLR, and GE districts and all buildings located within 500 feet of the R.O.W. of a freeway or major thoroughfare, as defined in the City's Master Plan for Land Use.		
Region 2	All buildings in districts other than I-1 and I-2, other than those in Region 1.		
Region 3	Buildings in I-1 and I-2 districts, other than those in Region 1.		
Maximum Allowable Percentages			
Wall Materials	Region 1	Region 2	Region 3
Brick, natural clay	100 ⁽⁸⁾	100	100
Brick, painted ⁽³⁾	0	0	0
Glazed brick & ceramic tile ⁽¹⁾	25	75	100
Limestone	50	100	100
Stone field, cobble, etc.	50	75	100
Granite, marble, polished	50	100	100
Fluted & split faces c.m.u. ^(2, 11)	10	50	75
Striated scored c.m.u. ^(2, 11)	0	0	25
Concrete "C" brick ⁽¹³⁾	25	50	75
Precast colored exposed agg.	0	25	50
Precast, other	0	0	0
Flat metal panels (urethane backed)	50 ⁽⁹⁾	50	75
Standing seam metal ⁽⁷⁾	25	50	75
Ribbed metal panels ⁽⁷⁾	0	25	50

DRAFT 06-12-2017

Spandrel glass	50	50	50
Glass block	0	25	50
Display glass	25	25	25
Molded cornices, trim, columns, surrounds	15	15	15
Wood siding, painted, t&g, and batten siding ⁽¹³⁾	0 ⁽¹⁰⁾	25 ⁽¹⁰⁾	50
Horizontal Clapboard, Dutch Lap vinyl & aluminum siding	0	0	0
Patterned/textured vinyl and polymer siding (scalloped, staggered shake, half round, fish scale, rough split, etc.)	25	25	25
E.I.F.S. (dryvit) ⁽⁵⁾	25	50	75
Cast stone & G.F.R.C.	25	50	75
Cement plaster	0	25	25
Awnings: Fabric or Membrane ⁽⁵⁾	10	15	15
Asphalt shingles	25 ⁽¹⁴⁾	25 ⁽¹⁴⁾	50

Referenced Notes to Table

1. Allowed only if earth tone color and matte finish.
2. Plain faced C.M.U.'s are not permitted. Ground, polished, burnished and striated faced C.M.U.'s are only permitted if laid in a stacked bond pattern.
3. Previously painted brick must meet color standards in paragraph 2 of this Section as determined by submission of color samples for façade consultant review.
4. Must be designed to simulate stone via joint pattern. Maximum joint spacing shall be three (3) feet on center horizontally and four (4) feet on center vertically.
5. Adjacent permanent facade materials shall extend behind awnings, backlit translucent awnings are not permitted except as regulated as a building sign.
6. Refer also to [Section 3.27.1.G](#) for additional TC and TC-1 districts facade requirements [Section 3.21.2.C](#) for additional PSLR overlay district facade requirements, and [Section 3.25.2.G](#) for additional EXO overlay district façade requirements.
7. Must have factory applied permanent colored finish.
8. All buildings in Region 1 shall have a minimum of thirty (30) percent brick.
9. Up to twenty-five (25) percent is allowed in the TC and TC-1 districts.
10. The percentage of wood siding may be increased to fifty (50) percent in zoning districts RA through R4, RM-1 and RM-2, when the use of wood siding is consistent with residential style architecture.
11. The combined maximum amount of all C.M.U. shall not be greater than 75% of any one building and/or facade.
12. Concrete "C" brick shall be a maximum size of 16" wide by 4" high. Color shall be rich dark earth tone hues consistent with brown or red bodied fired clay brick. Colors using white cement base and/or substantial quantities of light colored aggregate are not allowed.
13. Wood grain textured fibrous concrete siding shall be considered wood siding with respect to this ordinance.
14. Up to 50% allowed with residential style architecture or in R Districts. Asphalt shingles are prohibited on mansard style roofs.

General Notes to Table

- Roof areas having slopes 3:12 and greater shall be considered facades.
- Vision glass and doors shall be omitted from facade material area calculations and percentages.
- Detached single family dwellings are not subject to this Section. Refer to Section 3.7 for façade standards.
- Backlit translucent plastic, backlit awnings, neon lighting, LED string lighting, and other such facade materials designed to visually attract attention for the purpose of commercial activity are not permitted.

- Where vision glass areas are intended through exposure to thoroughfares or pedestrian ways and lighting methods to strongly emphasize the materials and items displayed within the window area, and where such items are a permanent part of the building design, such items shall be deemed as part of the building facade and shall be so regulated by this section.
- When a specific material is not listed in the table, then the façade consultant shall make a determination as to the most similar material listed.

PART II.

Severability. Should any section, subdivision, clause, or phrase of this Ordinance be declared by the courts to be invalid, the validity of the Ordinance as a whole, or in part, shall not be affected other than the part invalidated.

PART III.

Savings Clause. The amendment of the Novi Code of Ordinances set forth in this Ordinance does not affect or impair any act done, offense committed, or right accruing, accrued, or acquired or liability, penalty, forfeiture or punishment, pending or incurred prior to the amendment of the Novi Code of Ordinances set forth in this Ordinance.

PART IV.

Repealer. All other Ordinance or parts of Ordinance in conflict herewith are hereby repealed only to the extent necessary to give this Ordinance full force and effect.

PART V.

Effective Date: Publication. Public hearing having been held hereon pursuant to the provisions of Section 103 of Act 110 of the Public Acts of 2006, as amended, the provisions of this Ordinance shall be published within fifteen (15) days of its adoption by publication of a brief notice in a newspaper circulated in the City of Novi stating the date of enactment and effective date, a brief statement as to its regulatory effect and that a complete copy of the Ordinance is available for public purchase, use and inspection at the office of the City Clerk during the hours of 8:00 A.M. to 5:00 P.M., Local Time. The provisions of this Ordinance shall become effective seven (7) days after its publication.

MADE, PASSED, AND ADOPTED BY THE CITY COUNCIL OF THE CITY OF NOVI, OAKLAND COUNTY, MICHIGAN, ON THE ___ DAY OF _____, 2017.

ROBERT J. GATT, MAYOR

CORTNEY HANSON, CITY CLERK

Ayes:

Nays:

Abstentions:

Absent:

**TEXT AMENDMENT 18.281
FAÇADE ORDINANCE UPDATE
MARKED-UP VERSION**

STATE OF MICHIGAN
COUNTY OF OAKLAND
CITY OF NOVI
ORDINANCE NO. 17-18.281

AN ORDINANCE TO AMEND THE CITY OF NOVI CODE OF ORDINANCES, ORDINANCE 14-271, THE CITY OF NOVI ZONING ORDINANCE, ARTICLE 5.0 "SITE STANDARDS," SECTION 5.15, "EXTERIOR BUILDING WALL FAÇADE MATERIALS," TO CLARIFY AND UPDATE THE FAÇADE MATERIALS STANDARDS IN THE ZONING ORDINANCE.

THE CITY OF NOVI ORDAINS:

Part I. That the City of Novi Code of Ordinances, Ordinance 14-271, the Zoning Ordinance, is hereby amended, by amending Article 5.0, "Site Standards," Section 5.15, "Exterior Building Wall Façade Materials," to read as follows in its entirety:

Section 5.15 - EXTERIOR BUILDING WALL FAÇADE MATERIALS

Introductory paragraphs to section [Unchanged]

1. [Unchanged].
2. Color. Colors of all facade and roof materials proposed for a building reviewed under this Ordinance shall be established by the applicant as an integral part of the building design, and shall exhibit evidence of coordination and selection with respect to the overall visual effect of the building. The color of each facade material shall be harmonious with the color of all other facade materials used on the same building, as well as the color of facade materials used on adjacent buildings. For the purpose of this Ordinance, harmonious shall be defined as colors which are complementary in hue, tone, and intensity. The use of dissonant and/or intense colored facade materials shall be deemed inconsistent with this Section. The use of facade materials to form a background or component in a sign or to increase the visual presence of the building for the purpose of advertising [and the use of interior or exterior neon, LED, or flashing or changing-color illuminated features](#) shall be deemed inconsistent with this Section.
3. [Unchanged].
4. Submittals. The following shall be submitted to the Community Development Department. There shall be minimum requirements and the applicant may present other items, as may be deemed necessary by the applicant. All materials submitted shall be retained by the Community Development Department [until the final façade inspection is completed](#), shall become part of the approval documents for the project and may be used by the Community Development Department at a later date to determine compliance of the completed building.

A.- E. [Unchanged].

5. Facade Material Calculations. The facade (north, south, east, and west) of each regulated structure shall be considered separately for the purpose of calculating the percentages of materials for compliance with the Schedule Regulating Facade Materials. The materials on each facade shall be consistent with the materials on other facades of the same building with respect to type and color. Areas of sloped roofs with a slope of ~~six~~three to twelve (~~6~~3:12) or greater shall be considered facades. Areas of sloped roofs shall be taken as the horizontal projection of the roof area (as seen in elevation view). Areas of vision glass and operable doors shall be excluded from all area calculations.

6. Alterations. Where new materials are proposed for an existing building facade, the entire building facade shall be subject to this Section. Exception where horizontal offsets greater than two (2) feet occur in an existing facade which serve to visually separate the area within which the new materials are proposed, only the area between such offsets shall be subject to this Section, provided that the new materials and colors are harmonious with adjacent unaltered portions of the building, and provided that the building is not located in the TC or TC-1 district. A continuation of existing materials may be used on an alteration. Painting for maintenance that matches the exact color, does not require a permit. Painting for a color change requires review by the Community Development Department prior to work. Painting using colors that are inconsistent with Section 5.15.2 and painting of previously unpainted brick is not allowed.

7.-14. [Unchanged].

5.15 Schedule Regulating Façade Materials			
Façade Regions ⁽⁶⁾			
Region 1	Buildings located in the TC, TC-1 ⁽⁷⁾ , RC, RA, R, RM-1, RM-2, PSLR, and GE districts and all buildings located within 500 feet of the R.O.W. of a freeway or major thoroughfare, as defined in the City's Master Plan for Land Use.		
Region 2	All buildings in districts other than I-1 and I-2, other than those in Region 1.		
Region 3	Buildings in I-1 and I-2 districts, other than those in Region 1.		
Maximum Allowable Percentages			
Wall Materials	Region 1	Region 2	Region 3
Brick, natural clay	100 ⁽⁹⁾	100	100
<u>Brick, painted ⁽³⁾</u>	<u>0</u>	<u>0</u>	<u>0</u>
Glazed brick & ceramic tile ⁽¹⁾	25	75	100 ⁽⁴⁾
<u>Panel brick</u>	<u>0</u>	<u>15</u>	<u>15</u>
Limestone	50	100	100
Stone field, cobble, etc.	50	75	100
Granite, marble, polished	50	100	100
Fluted & split faces c.m.u. ^(2,11)	10	50	75 ^(2,13)
Striated scored c.m.u. ^(2,11)	0	0	25 ⁽²⁾⁽¹³⁾
Concrete "C" brick ⁽¹³⁾	25	50	75
Precast colored exposed agg.	0	25	50
Precast, other	0	0	0
Flat metal panels (urethane backed)	50 ⁽²⁾⁽⁴⁾	50	75
Standing seam metal ⁽⁷⁾	25 ⁽³⁾	50	75 ⁽⁸⁾

DRAFT 06-12-2017

Ribbed metal panels ⁽⁷⁾	0 ⁽⁸⁾	25	50 ⁽⁸⁾
Spandreal glass	50	50	50
Glass block	0	25	50
Display glass	25	25	25 ⁽⁴⁾
Molded cornices, trim, columns, surrounds	15	15	15
Wood siding, painted, t&g, and batten siding ⁽¹³⁾	0 ⁽¹¹⁰⁾	25 ⁽¹¹⁰⁾	50
<u>Horizontal Clapboard, Dutch Lap</u> vinyl & aluminum siding	0	0	<u>0</u> ⁽¹²⁾
<u>Patterned/textured vinyl and polymer siding (scaloped, staggered shake, half round, fish scale, rough split, etc.)</u>	<u>25</u>	<u>25</u>	<u>25</u>
E.I.F.S. (dryvit) ⁽⁵⁾	25	50	75 ⁽⁶⁾
Cast stone & G.F.R.C.	25	50	75
Cement plaster	0	25	25
<u>Canvas awnings-Awnings: Fabric or Membrane</u> ⁽⁵⁾	10	15	15 ⁽⁶⁾
Asphalt shingles	25 ⁽¹⁴⁾	25 ⁽¹⁴⁾	50

Referenced Notes to Table

1. Allowed only if earth tone color and matte finish.
2. Plain faced C.M.U.'s are not permitted. Ground, polished, burnished and striated faced C.M.U.'s are only permitted if laid in a stacked bond pattern.
- ~~3. Copper or Copper bearing painted finish is preferred in the TC and TC-1 districts. The Community Development Department may approve alternate colors or materials provided it is determined to be complementary to copper finish.~~
3. Previously painted brick must meet color standards in paragraph 2 of this Section as determined by submission of color samples for façade consultant review.
- ~~4. Where vision glass areas are intended through exposure to thoroughfares or pedestrian ways and lighting methods to strongly emphasize the materials and items displayed within the window area, and where such items are a permanent part of the building design, such items shall be deemed as part of the building facade and shall be so regulated by this section.~~
- ~~5.4.~~ Must be designed to simulate stone via joint pattern. Maximum joint spacing shall be three (3) feet on center horizontally and four (4) feet on center vertically.
- ~~6.5.~~ Adjacent permanent facade materials shall extend behind awnings, backlit translucent awnings are not permitted except as regulated as a building sign.
- ~~7.6.~~ Refer also to Section 3.27.1.G for additional TC and TC-1 districts facade requirements, ~~and~~ Section 3.21.2.C for additional PSLR overlay district facade requirements, ~~and~~ Section 3.25.2.G for additional EXO overlay district facade requirements.
- ~~8.7.~~ Must have factory applied permanent colored finish.
- ~~9.8.~~ All buildings in Region 1, ~~except those in I-1 and I-2 districts,~~ shall have a minimum of thirty (30) percent brick.
- ~~10.9.~~ Zero (0) percent ~~Up to twenty-five (25) percent is~~ allowed in the TC and TC-1 districts.
- ~~11.10.~~ The percentage of wood siding may be increased to fifty (50) percent in zoning districts RA through R4, RM-1 and RM-2, when the use of wood siding is consistent with residential style architecture.
- ~~12. One eighths (1/8) inch gauge wood grain textured solid vinyl siding is permitted in R Districts only and three eighths (3/8) inch gauge wood grain textured fibrous concrete siding shall be considered wood siding with respect to this ordinance.~~
- ~~13.11.~~ The combined maximum amount of all C.M.U. shall not be greater than 75% of any one building and/or facade.
12. Concrete "C" brick shall be a maximum size of 16" wide by 4" high. Color shall be rich dark earth tone hues consistent with brown or red bodied fired clay brick. Colors using white cement base and/or substantial quantities of light colored aggregate are not allowed.
- ~~14.13.~~ Wood grain textured fibrous concrete siding shall be considered wood siding with

[respect to this ordinance.](#)

[15-14. Up to 50% allowed with residential style architecture or in R Districts. Asphalt shingles are prohibited on mansard style roofs.](#)

General Notes to Table

- Roof areas having slopes ~~6~~3:12 and greater shall be considered facades.
- Vision glass and doors shall be omitted from facade material area calculations and percentages.
- Detached [single family](#) dwellings are not subject to ~~facade chart~~[this Section. Refer to Section 3.7 for façade standards.](#)
- Backlit translucent plastic, backlit awnings, neon lighting, [LED string lighting](#), and other such facade materials designed to visually attract attention for the purpose of commercial activity are not permitted ~~(or shall be considered signage).~~
- [Where vision glass areas are intended through exposure to thoroughfares or pedestrian ways and lighting methods to strongly emphasize the materials and items displayed within the window area, and where such items are a permanent part of the building design, such items shall be deemed as part of the building facade and shall be so regulated by this section.](#)
- [When a specific material is not listed in the table, then the façade consultant shall make a determination as to the most similar material listed.](#)

PART II.

Severability. Should any section, subdivision, clause, or phrase of this Ordinance be declared by the courts to be invalid, the validity of the Ordinance as a whole, or in part, shall not be affected other than the part invalidated.

PART III.

Savings Clause. The amendment of the Novi Code of Ordinances set forth in this Ordinance does not affect or impair any act done, offense committed, or right accruing, accrued, or acquired or liability, penalty, forfeiture or punishment, pending or incurred prior to the amendment of the Novi Code of Ordinances set forth in this Ordinance.

PART IV.

Repealer. All other Ordinance or parts of Ordinance in conflict herewith are hereby repealed only to the extent necessary to give this Ordinance full force and effect.

PART V.

Effective Date: Publication. Public hearing having been held hereon pursuant to the provisions of Section 103 of Act 110 of the Public Acts of 2006, as amended, the provisions of this Ordinance shall be published within fifteen (15) days of its adoption by publication of a brief notice in a newspaper circulated in the City of Novi stating the date of enactment and effective date, a brief statement as to its regulatory effect and that a complete copy of the Ordinance is available for public purchase, use and inspection at the office of the City Clerk during the hours of 8:00 A.M. to 5:00 P.M., Local Time. The provisions of this Ordinance shall become effective seven (7) days after its publication.

DRAFT 06-12-2017

MADE, PASSED, AND ADOPTED BY THE CITY COUNCIL OF THE CITY OF NOVI, OAKLAND COUNTY, MICHIGAN, ON THE ___ DAY OF _____, 2017.

ROBERT J. GATT, MAYOR

CORTNEY HANSON, CITY CLERK

Ayes:

Nays:

Abstentions:

Absent:

PUBLIC COMMENT FROM ARCHITECTS

Mellem, Kirsten

From: Matt Niles <mniles@wahyeeassoc.com>
Sent: Monday, May 15, 2017 2:20 PM
To: McBeth, Barb
Cc: 'Doug Necci'; Mellem, Kirsten
Subject: RE: Facade Ordinance updates - comments requested

Barbara ;

I think the proposed changes are all good, I would however still like to see a little more of the "Flat Metal Panels" allowable in the TC and TC1 districts. The metal panel system that we have used is a very high quality material, superior to E.I.F.S. in many ways, 15% is not much, especially when compared to the 25% E.I.F.S. allowable in these districts.

Thank you for allowing me to have a voice regarding the new façade ordinance, it is greatly appreciated. I may not speak for everyone, but I think it is a pleasure to work in Novi these days.

Matt Niles
Senior Project Designer
Wah Yee Associates Architects

From: McBeth, Barb [<mailto:bmbeth@cityofnovi.org>]
Sent: Monday, April 24, 2017 2:13 PM
Cc: 'Doug Necci'; Mellem, Kirsten
Subject: Facade Ordinance updates - comments requested

Good Afternoon!

You are receiving this email as an architect who has recently done business with the Planning staff at Novi's Community Development Department. We want to let you know that we have proposed some changes to the Façade Section of the City of Novi's Zoning Ordinance and are seeking any and all comments at this time. Here is a [link](#) to the packet that was recently considered by the Planning Commission.

Feel free to email me your comments and we will include a summary of comments to the City Council as the ordinance amendments proceed for consideration by the City Council in a couple of weeks.

Thanks,
Barb



Barbara McBeth, AICP | City Planner

City of Novi | 45175 W. Ten Mile Road | Novi, MI 48375 USA
t: 248.347.0587 c: 248.343.1237 f: 248.735.5633

cityofnovi.org | InvestNovi.org

To receive monthly e-news from Novi or follow us on Facebook, [click here](#).

**SECTION 9 FAÇADE WAIVER REVIEW
FOR 2015-2016**

Section 9 Façade Waivers

* PRO/SDO/PSLR agreements have not been included

PC Date	JSP	Project	Waivers	Material Waivers
11/16/2016	16-55	American Interiors	To allow the overage of Flat Metal Panels (50% allowed; 58% on south, 86% on east, 57% on west and 83% on north proposed), Wood Siding (0% allowed, 36% on south, 8% on east, 40% on west and 11% on north proposed), and Exposed Concrete (4% on east and 2% on north proposed), because the proposed alteration will significantly improve the overall appearance of the building and is consistent with the intent and purpose of the Façade Ordinance.	flat metal panels, wood siding, exposed concrete
11/16/2016	16-50	Goddard School	Section 9 Façade waiver from Section 5.15 to permit the overage of Asphalt Shingles on all sides (25% maximum, 32%, 48%, 47%, and 41% provided) of required maximum due to architectural roof style that is augmented by architectural features including dormers and a decorative cupola.	asphalt shingles
10/5/2016	16-43	Rainbow Day Care	A Section 9 Façade waiver for overage of Asphalt Shingles on all sides (25% maximum, 43 % - 46 % provided) and Cement Composite Siding (0% maximum, 3% - 5% provided).	asphalt shingles, cement composite siding
9/28/2016	16-34	Huntley Manor	Section 9 Façade waiver for underage of brick on the side elevations and overage of asphalt shingles; 30% min, 15% provided brick on the side; 25% maximum, 30-50% provided asphalt shingles; 30-38% asphalt shingles on the clubhouse, maximum is 25%.	brick, asphalt shingles
9/14/2016	14-40	ATI Façade	To allow the overage of Cast Stone and Stone Veneer (50% allowed; 84% to 92% provided) because the proposed combination of Cast Stone and Stone Veneer is consistent with and enhances the overall design of the building, and is consistent with the intent and purpose of the Façade Ordinance.	cast stone/stone veneer
7/27/2016	16-12	Suburban Collection Showplace	A section 9 façade waiver for the overage of Horizontal Rib Metal Panels(0% allowed, a maximum 15% on south, 5% on North, 3% on east and 8% on west provided), Vertical Metal Panels(50% allowed, 60% on north and east side provided) and Split Faced CMU(10% allowed, 15% on south, 35% on North, 24% on east and 43% on west provided).	horizontal rib metal panels, vertical metal panels, split faced CMU
6/22/2016	16-17	Pine Ridge Façade	To allow the overage of EIFS material (25% allowed; 57% & 51% provided) and the underage of Brick material (30% minimum; 29% provided) because the proposed alteration will significantly improve the overall appearance of the building and is consistent with the intent and purpose of the Façade Ordinance.	EIFS, brick

PC Date	JSP	Project	Waivers	Material Waivers
5/25/2016	15-77	Town Center Gardens	To allow the overage of cement board siding (Allowed: 0 percent; Proposed: 12 percent on west (front), 9 percent on east, and 20 percent on north), because the proposed cement board siding will have a color and texture similar to natural wood and is contingent upon completion of the crescent shaped outdoor seating area.	cement board siding
3/23/2016	15-81	Maly Dental	To allow the overage of asphalt shingles (25% allowed; 50%, 59%, 52%, and 58% proposed) because the proposed design will mitigate the expanse of asphalt shingles, which is hereby granted; b. To allow the underage of stone or brick (30% minimum allowed; 18%, 25%, and 20% proposed) because the percentage of stone is consistent with the window sill line and increasing the percentage would not add to the aesthetic quality of the design.	asphalt shingles, stone/brick
1/27/2016	16-02	Pavilion Shore Park Shelter	To allow the underage of brick on all sides (30 percent minimum required, 0% proposed), overage of cementitious siding on east and west facades (50% maximum allowed, 66 and 62 percent proposed respectively), overage of Wood Trim on east and west facades (15 percent maximum allowed, 18 and 21 percent proposed respectively) and overage of Asphalt Shingles on north and south facades (25 percent maximum allowed, 86 percent proposed respectively) because the deviations are justified on the basis of historical context and the design is consistent with the intent and purpose of the Façade Ordinance, which is hereby granted	brick, siding, wood trim, asphalt shingles
11/4/2015	15-66	Legacy Church Façade	To allow the overage of single score CMU material on all façades (25% allowed; 71%, 48%, 44% and 59% proposed) because the proposed alteration will significantly improve the overall appearance of the building and is consistent with the intent and purpose of the Façade Ordinance, which is hereby granted. The CMU block is existing but will be painted and complemented with additional materials.	CMU
6/24/2015	15-40	Novi Plaza Façade	To allow the overage of EIFS material on the north façade (25% allowed; 32% provided) because the proposed alteration will significantly improve the overall appearance of the building and is consistent with the intent and purpose of the Façade Ordinance.	EIFS
6/24/2015	15-27	Kroger Retail Fuel Center	A section 9 waiver required for overage of EIFS on the building and underage of brick on the canopy.	EIFS, brick
6/10/2015	15-07	Brightmoor Church	To allow the overage of flat metal panels on the north façade because of the fact that the north façade is not directly visible from a major thoroughfare and is of a less visual significance and therefore do not represent a violation of the Façade Ordinance.	flat metal panels

PC Date	JSP	Project	Waivers	Material Waivers
4/8/2015	13-16	Big Boy	Section 9 waiver to allow an underage of brick and overage of EIFS.	EIFS, brick
4/8/2015	15-23	Belle Tire	To allow the overage of Standing Seam Metal on the basis that the deviation from the Ordinance is results from existing construction and does not detract for the appearance of the building. The proposed modifications represent a significant enhancement to the overall aesthetic quality of the building.	standing seam metal
2/25/2015	14-10	Neptune Center	Section 9 Waiver for underage of brick and overage of CMU on all facades provided the applicant works with the City's façade consultant to determine an appropriate color pigment for the proposed CMU product.	brick, CMU
2/11/2015	JC14-1	DICE Holdings	To allow the overage of Stucco Panels and Asphalt Shingles on the basis that the stucco panels are existing and the surplus of Asphalt Shingles is relatively small. The overall visual affect will be a significant improvement in the appearance of the building.	stucco panels, asphalt shingles
2/11/2015	14-68	Sunbelt Rentals	To allow the overage of Ribbed Metal, EIFS and Embossed Metal Panels on the basis that the Ribbed Metal Panels and EIFS are existing materials and therefore do not represent a violation of the Façade Ordinance.	ribbed metal, EIFS, embossed metal panels